


ARKANSAS REGISTER

Transmittal Sheet

Use only for **FINAL** and **EMERGENCY RULES**



Secretary of State

Mark Martin

500 Woodlane, Suite 026

Little Rock, Arkansas 72201-1094

(501) 682-5070

www.sos.arkansas.gov



For Office

Use Only:

Effective Date _____ Code Number _____

Name of Agency Arkansas Department of Labor

Department Board of Electrical Examiners

Contact Denise P. Oxley E-mail denise.oxley@arkansas.gov Phone (501) 682-4502

Statutory Authority for Promulgating Rules Ark. Code Ann. 20-31-104

Rule Title: Rule 010.13-008. The National Electrical Code

Intended Effective Date

(Check One)

☐ Emergency (ACA 25-15-204)

☐ 10 Days After Filing (ACA 25-15-204)

☒ Other January 1, 2018
(Must be more than 10 days after filing date.)

Legal Notice Published 7/27/17-7/29/2017

Final Date for Public Comment 9/19/2017

Reviewed by Legislative Council 12/12/2017

Adopted by State Agency 9/19/2017

Electronic Copy of Rule e-mailed from: (Required under ACA 25-15-218)

Denise P. Oxley denise.oxley@arkansas.gov

Contact Person

E-mail Address

December 14, 2017

Date

CERTIFICATION OF AUTHORIZED OFFICER

I Hereby Certify That The Attached Rules Were Adopted
In Compliance with the Arkansas Administrative Act, (ACA 25-15-201 et. seq.)

Leon Jones
Signature

501-682-4541

leon.jones@arkansas.gov

Phone Number

E-mail Address

Director of Labor, State of Arkansas

Title

December 14, 2017

Date

FILED
AN REGISTER DIV.
2017 DEC 14 AM 11:38
MARK MARTIN
SECRETARY OF STATE
STATE OF ARKANSAS

**ADMINISTRATIVE REGULATIONS OF
THE BOARD OF ELECTRICAL EXAMINERS,
STATE OF ARKANSAS**

**010.13 Administrative Regulations of the Board of Electrical Examiners of the State of
Arkansas**

Amendment 1. Amend Rule 010.13-008 (A) and (B), dealing with the National Electrical Code, to read as follows:

010.13-008 The National Electrical Code

- A. The Board hereby adopts and incorporates herein the National Electrical Code, 2017 edition of the National Fire Protection Association.
- B. The National Electrical Code, 2017, shall be the standard for the construction, installation, repair, and maintenance of electrical facilities and the performance of electrical work.
1. Notwithstanding the provisions of the 2017 National Electrical Code, arc fault circuit interrupters shall not be required in kitchens and laundry rooms.

Amendment 2. Amend Rule 010.13-023 to read as follows:

010.13-023 Effective Date, Repealer and History.

- A. Effective June 1, 2008 all previous regulations promulgated by the Board are hereby repealed.
- B. The effective date of these regulations is June 1, 2008.
- C. History
1. The Board of Electrical Examiners first promulgated regulations effective September 12, 1979. These regulations were amended effective October 15, 1987.
2. All previous rules and regulations of the Board were repealed and new rules and regulations were adopted effective January 1, 1992. These regulations were amended effective January 19, 1993; September 29, 1993; January 15, 1996; June 1, 1999; and July 1, 1999.

2017 DEC 14 11:38
FILED
AR REGISTRY DIV.
JAN MATHIAS
SECRETARY
STATE OF ARKANSAS

3. All previous rules and regulations of the Board were repealed and new rules and regulations were adopted effective September 1, 1999. These regulations were amended effective August 20, 2001; January 1, 2002; April 1, 2002; April 1, 2004; November 1, 2004; October 1, 2005; and June 1, 2006.

4. All previous rules and regulations of the Board of Electrical Examiners were repealed and new rules and regulations were adopted effective June 1, 2008. [Note: Rule 010.13-019 was amended effective September 1, 2008 by adding subsection (E)].

5. Regulations 010.13-009, 010.13-011, and 010.13-012 pertaining to Specialist Sign Electricians and examination fees were amended by emergency regulation effective July 31, 2009. These changes were adopted as permanent regulations effective February 1, 2010. Regulation 010.13-012(H)(5) was also added by the permanent regulation.

6. Effective September 15, 2011 the following Rules were amended: Rule 010.13-008(B)(to update the National Electrical Code to the 2011 edition).

7. Regulation 010.13-021 pertaining to the licensure of electrical inspectors, was adopted with an effective date of February 10, 2014.

8. Effective November 21, 2014, Rule 010.13-008 was amended to update the National Electrical Code to the 2014 edition, with certain exceptions (dealing with arc fault circuit interrupters in kitchen and laundry rooms).

9. Effective January 1, 2016, the following Rules were amended: Rule 010.13-002 (Information for public guidance); Rule 010.13-004 (Rule-making); Rule 010.13-005 (Emergency rule-making); Rule 010.13-009 (Definitions); and Rule 010.13-013 (Licenses). A new rule was adopted effective January 1, 2016, Rule 010.13-022 (Active duty service members, returning military veterans, and spouses).

10. Effective June 1, 2017, Rule 010.13-008 was amended to adopt Article 691, Large-Scale Photovoltaic (PV) Power Production Facility, 2017 edition of the National Electrical Code as an emergency rule.

11. Effective January 1, 2018, Rule 010.13-008 was amended to update to the 2017 edition of the National Electrical Code, with certain exceptions (dealing with arc fault circuit interrupters in kitchen and laundry rooms).