


ARKANSAS REGISTER



Transmittal Sheet

Use only for **FINAL** and **EMERGENCY RULES**

Secretary of State

Mark Martin

500 Woodlane, Suite 026

Little Rock, Arkansas 72201-1094

(501) 682-5070

www.sos.arkansas.gov



For Office

Use Only:

Effective Date _____ Code Number _____

Name of Agency Arkansas State Police

Department Regulatory & Building Operations

Contact Major Lindsey Williams E-mail lindsey.williams@asp.arkansas.gov Phone 501-618-8600

Statutory Authority for Promulgating Rules A.C.A. 12-13-105(5)

Rule Title: Residential Daycare Exception

Intended Effective Date
(Check One)

Date

☐ Emergency (ACA 25-15-204)

Legal Notice Published Sept 12, 2016

☒ 10 Days After Filing (ACA 25-15-204)

Final Date for Public Comment Oct 12, 2016

☐ Other _____
(Must be more than 10 days after filing date.)

Reviewed by Legislative Council Dec 13, 2016

Adopted by State Agency Dec 13, 2016

Electronic Copy of Rule e-mailed from: (Required under ACA 25-15-218)

Major Lindsey Williams

lindsey.williams@asp.arkansas.gov

Dec 13, 2016

Contact Person

E-mail Address

Date

CERTIFICATION OF AUTHORIZED OFFICER

I Hereby Certify That The Attached Rules Were Adopted
In Compliance with the Arkansas Administrative Act. (ACA 25-15-201 et. seq.)

[Signature]

Signature

501-618-8600

Phone Number

Michael.Mayer@asp.arkansas.gov

E-mail Address

Sergeant

Title

12/13/16

Date

FILED
AR REGISTER DIV.
2016 DEC 13 PM 2:13
MARK MARTIN
SECRETARY OF STATE
STATE OF ARKANSAS

RESIDENTIAL DAYCARE EXCEPTION
2012 ARKANSAS FIRE PREVENTION CODE

....

[M] 609.2 Where required. A Type 1 hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease vapors. A residential hood is allowed for protection of domestic cooking appliances in child care facilities.

Exception: Residential hoods are not required in day care facilities licensed for sixteen (16) or less, when operated in the care giver's primary residence and the cooking performed during the hours of day care operation does not produce grease vapors.

609.2.1 Where required – retroactive in existing buildings or structures. A residential hood shall be installed in all child care facilities by January 1, 2017.

....

904.2.1 Commercial hood and duct systems. Each commercial kitchen exhaust hood and duct system required by Section 609 to have a Type I hood or residential hood shall be protected with an *approved* automatic fire-extinguishing system installed in accordance with this code.

Exception: Automatic fire extinguishing systems are not required in day care facilities licensed for sixteen (16) or less, when operated in the care giver's primary residence and the cooking performed during the hours of day care operation does not produce grease vapors.

FILED
AR REGISTER DIV.
2016 DEC 13 PM 2:13
MARK MARTIN
SECRETARY OF STATE
STATE OF ARKANSAS
BY _____